



Agenda Commentary

Item Title/ Subject: Water Treatment Plant Filter Control Panel

Staff Source: Arnold Adams, Public Works Director

History/Background Information: This control panel was damaged due to a chlorine leak at the water plant and cannot be repaired

Item/Subject Summary: Due to the damage to this control panel caused by the chlorine leak at the Water Treatment Plant filters cannot be backwashed. Because filters cannot be backwashed the plant cannot run. The purchase of this equipment should be reimbursable by the chemical provider or City of Clinton insurance company.

Price/Cost: Not to exceed \$50,000.00. We are in the process of taking quotes with 1 received and 2 more expected. (We hope to have all the quotes before the council meeting)

Recommendation: Repairs need to be made immediately even though presently the water plant is not in operation. In order to be prepared in the event Foss should go down we need to be ready to get the water plant back up and running.