

PROCESS MEETING FOR PERMIT APPLICATION FILED WITH THE OKLAHOMA
DEPARTMENT OF ENVIRONMENTAL QUALITY

In accordance with Oklahoma Administrative Code ("OAC") 252:4-7-78(3), the City of Clinton located at 415 Gary Boulevard, P.O. Box 1177, Clinton, Oklahoma 73601-1177, has filed a Tier III permit application for a Class V Drinking Water Treatment Residuals (DWTR) injection well with the Oklahoma Department of Environmental Quality (DEQ). Interested persons now have the opportunity to meet with DEQ to learn how and where they may participate in the permitting process. The facility is located in the SE/4, SE/4, SW/4 of Section 16, Township 12 North, Range 17 West, Custer County, Oklahoma.

The proposed permit, if issued, will allow the City of Clinton to operate a facility to inject DWTR from its water treatment plant pursuant to the Safe Drinking Water Act, the Water Quality provisions of the Oklahoma Environmental Quality Code (27A O.S. § 2-2-101 *et seq.* and § 2-6-701), the Oklahoma Underground Injection Control Rules at Oklahoma Administrative Code 252:652-1 *et seq.* and applicable portions of Title 40, Code of Federal Regulations, incorporated therein by reference.

The applicant requests approval to operate a Class V DWTR injection well to a depth of 9,600 feet with the disposal zone between 8,120 and 9,480 feet. The waste is brine with an estimated Total Dissolved Solids content of 8,000 to 12,000 mg/L generated from the treatment of drinking water.

A representative of DEQ will chair a meeting to explain the steps of DEQ's permitting process to interested persons. At this meeting, there will be discussion explaining when oral and written public comments can be made on the proposal. Administrative hearing opportunities will also be discussed. The meeting date and location is listed below.

Tuesday, February 16, 2016 at 6 p.m.
Clinton City Hall
415 West Gary Boulevard
Clinton, Oklahoma

The permit application may be reviewed during normal business hours at the following locations:

1. City of Clinton, City Hall, 415 Gary Boulevard, Clinton, Oklahoma 73601-1177.
2. Oklahoma Department of Environmental Quality, Office of Central Records, 707 N. Robinson, Oklahoma City, OK 73101.

The application may also be viewed online at <http://www.deq.state.ok.us/lpdnew/DraftPermits/ppp.html>

The DEQ contact person is:

Hillary Young, P.E.
Chief Engineer
Land Protection Division
P.O. Box 1677, Oklahoma City, OK, 73101-1677
(405) 702-5100

The applicant contact person is:

Mark Skiles
415 West Gary Boulevard
Clinton, Oklahoma, 73601
580-323-0217