



SCOTT A. THOMPSON
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN
Governor

October 12, 2016

Mr. Mark Skiles, City Manager
City of Clinton
PO Box 1177
Clinton, Oklahoma 73601-1177

Re: Amended Permit No. SL000020160214
Clinton Commerce Center: Sanitary Sewer Line
Facility No. 1010828

Dear Mr. Skiles:

Enclosed is Amended Permit No. SL000020160214 for the construction of 4,200 linear feet of eight (8) inch PVC sewer line, 2,400 linear feet of four (4) inch PVC sewer force main, a 150 gpm lift station, and all appurtenances to serve the City of Clinton, Custer County, Oklahoma.

The project authorized by this amended permit should be constructed in accordance with the plans approved by this Department on October 12, 2016. Any deviations from the approved plans and specifications affecting capacity, flow or operation of units must be approved, in writing, by the Department before changes are made.

Receipt of this amended permit should be noted in the minutes of the next regular meeting of the City of Clinton, after which it should be made a matter of permanent record.

We are returning one (1) set of the approved plans to you, one (1) set to your engineer and retaining one (1) set for our files.

Respectfully,

A handwritten signature in black ink that reads "Arya Simon".

Arya Simon, E.I.
Construction Permit Section
Water Quality Division

AS/RC/ag

Enclosure

c: Bill Kropf, Regional Manager, DEQ
BURNS FLAT DEQ OFFICE
Joseph M. Ridley, P.E., , C/O City of Clinton





SCOTT A. THOMPSON
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN
Governor

AMENDED PERMIT No. SL000020160214

SEWER LINES

FACILITY No. 1010828

PERMIT TO CONSTRUCT

- 7) That the permittee will take steps to assure that the connection of house services to the sewers is done in such a manner that the functioning of the sewers will not be impaired and that earth and ground water will be excluded from the sewers when the connection is completed.
- 8) That any deviations from approved plans or specifications affecting capacity, flow or operation of units must be approved by the Department before any such deviations are made in the construction of this project.
- 9) That the recipient of the amended permit is responsible for the continued operation and maintenance of these facilities in accordance with rules and regulations adopted by the Environmental Quality Board, and that this Department will be notified in writing of any sale or transfer of ownership of these facilities.
- 10) The issuance of this amended permit does not relieve the responsible parties of any obligations or liabilities which the permittee may be under pursuant to prior enforcement action taken by the Department.
- 11) That the permittee is required to inform the developer/builder that a DEQ Storm Water Construction Permit is required for a construction site that will disturb one (1) acre or more in accordance with OPDES, 27A O.S. 2-6-201 *et. seq.* For information or a copy of the GENERAL PERMIT (OKR10) FOR STORM WATER DISCHARGES FROM CONSTRUCTION ACTIVITIES, Notice of Intent (NOI) form, Notice of Termination (NOT) form, or guidance on preparation of a Pollution Prevention Plan, contact the Storm Water Unit of the Water Quality Division at P.O. Box 1677, Oklahoma City, OK 73101-1677 or by phone at (405) 702-8100.
- 12) That all manholes shall be constructed in accordance with the standards for Water Pollution Control Facility Construction (OAC 252:656-5-3), as adopted by the Oklahoma Department of Environmental Quality.
- 13) That when it is impossible to obtain proper horizontal and vertical separation as stipulated in Water Pollution Control Facility Construction OAC 252:656-5-4(c)(1) and OAC 252:656-5-4(c)(2), respectively, the sewer shall be designed and constructed equal to water pipe, and shall be pressure tested using the ASTM air test procedure with no detectable leakage prior to backfilling, in accordance with the standards for Water Pollution Control Facility Construction OAC 252:656-5-4(c)(3).

