



SCOTT A. THOMPSON  
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN  
Governor

October 12, 2016

Mr. Mark Skiles, City Manager  
City of Clinton  
PO Box 1177  
Clinton, Oklahoma 73601-1177

Re: Amended Permit No. WL000020160213  
Clinton Commerce Center: Waterline  
Facility No. 1010828

Dear Mr. Skiles:

Enclosed is Amended Permit No. WL000020160213 for the construction of 6,750 linear feet of eight (8) inch PVC waterline and all appurtenances to serve the City of Clinton, Custer County, Oklahoma.

The project authorized by this amended permit should be constructed in accordance with the plans approved by this Department on October 12, 2016. Any deviations from the approved plans and specifications affecting capacity, flow or operation of units must be approved, in writing, by the Department before changes are made.

Receipt of this amended permit should be noted in the minutes of the next regular meeting of the City of Clinton, after which it should be made a matter of permanent record.

We are returning one (1) set of the approved plans to you, one (1) set to your engineer and retaining one (1) set for our files.

Respectfully,

A handwritten signature in black ink that reads "Arya Simon".

Arya Simon, E.I.  
Construction Permit Section  
Water Quality Division

AS/RC/ag

Enclosure

c: Bill Kropf, Regional Manager, DEQ  
BURNS FLAT DEQ OFFICE  
Joseph M. Ridley, P.E., C/O City of Clinton





SCOTT A. THOMPSON  
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN  
Governor

AMENDED PERMIT No. WL000020160213

WATER LINES

FACILITY No. 1010828

PERMIT TO CONSTRUCT

- 7) That before placing this facility into service, at least two samples of the water, taken on different days, shall be tested for bacteria to show that it is safe for drinking purposes.
- 8) That any deviations from approved plans or specifications affecting capacity, flow or operation of units must be approved by the Department before any such deviations are made in the construction of this project.
- 9) That the recipient of the amended permit is responsible for the continued operation and maintenance of these facilities in accordance with rules and regulations adopted by the Environmental Quality Board, and that this Department will be notified in writing of any sale or transfer of ownership of these facilities.
- 10) The issuance of this amended permit does not relieve the responsible parties of any obligations or liabilities which the permittee may be under pursuant to prior enforcement action taken by the Department.
- 11) That the permittee is required to inform the developer/builder that a DEQ Storm Water Construction Permit is required for a construction site that will disturb one (1) acre or more in accordance with OPDES, 27A O.S. Section 2-6-201 *et seq.* For information or a copy of the GENERAL PERMIT (OKR10) FOR STORM WATER DISCHARGES FROM CONSTRUCTION ACTIVITIES, Notice of Intent (NOI) form, Notice of Termination (NOT) form, or guidance on preparation of a Pollution Prevention Plan, contact the Storm Water Unit of the Water Quality Division at P.O. Box 1677, Oklahoma City, OK 73101-1677 or by phone at (405) 702-8100.
- 12) That any notations or changes recorded on the official set of plans and specifications in the Oklahoma Department of Environmental Quality files shall be part of the plans as approved.
- 13) That water lines shall be located at least fifteen (15) feet from all parts of septic tanks and absorption fields, or other sewage treatment and disposal systems.
- 14) That whenever plastic pipe is approved and used for potable water, it shall bear the seal of the National Sanitation Foundation and meet the appropriate commercial standards.

