



SCOTT A. THOMPSON  
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN  
Governor

February 16, 2017

RECEIVED  
2/22/17

Mark Skiles, City Manager  
City of Clinton  
415 Gary Boulevard  
Clinton, Oklahoma 73601

Re: Permit No.: SL000020170002  
Reverse Osmosis Water Treatment Plant  
Non-Industrial Wastewater/Sewer Force Main Project  
Facility No.: S-10804

Dear Mr. Skiles:

Enclosed is Permit No.: SL000020170002 for the construction of approximately 1,635 L. F. of four (4) inch non-industrial wastewater/sewer offsite force main and appurtenances to serve the City of Clinton Non-Industrial Wastewater/Sewer Force Main Project, Custer County, Oklahoma.

The project authorized by this permit should be constructed in accordance with the plans approved by this Department on February 16, 2017. Any deviations from the approved plans and specifications affecting capacity, flow, or operation of units must be approved, in writing, by the Department before changes are made.

Receipt of this permit should be noted in the minutes of the next regular meeting of the City of Clinton, after which it should be made a matter of permanent record.

We are returning one (1) set of the approved plans to you, one (1) set to your engineer and retaining one (1) set for our files.

Respectfully,

Robert Walker  
Construction Permit Section  
Water Quality Division

RBW/RC/ag

Enclosure

c: Burns Flat DEQ Office  
Bill Kropf, R. S., Regional Manager, DEQ  
Tyler McGown, P. E., Burns & McDonnell Engineering Company, Inc.





SCOTT A. THOMPSON  
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN  
Governor

**PERMIT NO.: SL000020170002**

**SEWER LINES**

**FACILITY NO.: S-10804**

**PERMIT TO CONSTRUCT**

February 16, 2017

Pursuant to O.S. 27A 2-6-304, the City of Clinton is hereby granted this Tier I Permit to construct approximately 1,635 L. F. of four (4) inch non-industrial wastewater/sewer offsite force main and appurtenances to serve the City of Clinton Non-Industrial Wastewater/Sewer Force Main Project, located in part of SE-1/4, SW-1/4, SE-1/4 Section 16, T-12-N, R-17-W, I. M., Custer County, Oklahoma, in accordance with the plans approved on February 16, 2017.

By acceptance of this permit, the permittee agrees to operate and maintain the facilities in accordance with the "Oklahoma Pollutant Discharge Elimination System Standards - OPDES" (OAC 252:606) rules and to comply with the state certification laws, Title 59, Section 1101-1116 O.S. and the rules and regulations adopted thereunder regarding the requirements for certified operators.

This permit is issued subject to the following provisions and conditions.

- 1) That the recipient of the permit is responsible that the project receives supervision and inspection by competent and qualified personnel.
- 2) That construction of all phases of the project will be started within one year of the date of approval or the phases not under construction will be resubmitted for approval as a new project.
- 3) That no significant information necessary for a proper evaluation of the project has been omitted or invalid information has been presented in applying for the permit.
- 4) That tests will be conducted as necessary to insure that the construction of the sewer lines will prevent excessive infiltration and that the leakage will not exceed 10 gallons per inch of pipe diameter per mile per day.
- 5) That the Oklahoma Department of Environmental Quality shall be kept informed of occurrences which may affect the eventual performance of the works or that will unduly delay the progress of the project.
- 6) That the permittee will take steps to assure that the connection of house services to the sewers is done in such a manner that the functioning of the sewers will not be impaired and that earth and ground water will be excluded from the sewers when the connection is completed.
- 7) That any deviations from approved plans or specifications affecting capacity, flow, or operation of units must be approved by the Department before any such deviations are made in the construction of this project.

Page 1 of 2





SCOTT A. THOMPSON  
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN  
Governor

**PERMIT NO.: SL000020170002**

**SEWER LINES**

**FACILITY NO.: S-10804**

**PERMIT TO CONSTRUCT**

- 8) That the recipient of the permit is responsible for the continued operation and maintenance of these facilities in accordance with rules and regulations adopted by the Environmental Quality Board, and that this Department will be notified in writing of any sale or transfer of ownership of these facilities.
- 9) The issuance of this permit does not relieve the responsible parties of any obligations or liabilities which the permittee may be under pursuant to prior enforcement action taken by the Department.
- 10) That the permittee is required to inform the developer/builder that a DEQ Storm Water Construction Permit is required for a construction site that will disturb one (1) acre or more in accordance with OPDES, 27A O.S. 2-6-201 *et. seq.* For information or a copy of the GENERAL PERMIT (OKR10) FOR STORM WATER DISCHARGES FROM CONSTRUCTION ACTIVITIES, Notice of Intent (NOI) form, Notice of Termination (NOT) form, or guidance on preparation of a Pollution Prevention Plan, contact the Storm Water Unit of the Water Quality Division at P.O. Box 1677, Oklahoma City, OK 73101-1677 or by phone at (405) 702-8100.
- 11) That all manholes shall be constructed in accordance with the standards for Water Pollution Control Facility Construction (OAC 252:656-5-3), as adopted by the Oklahoma Department of Environmental Quality.
- 12) That installed force main pipe design working pressure of the pipe must not exceed 2/3 of the rated pressure of the pipe and shall be tested for leakage in accordance with applicable ASTM standards specifications.
- 13) That any notations or changes recorded on the official set of plans and specifications in the Oklahoma Department of Environmental Quality files shall be part of the plans as approved.

Failure to appeal the conditions of this permit in writing within 30 days from the date of issue will constitute acceptance of the permit and all conditions and provisions.

---

Rocky Chen, P.E., Engineering Manager, Construction Permit Section  
Water Quality Division

Page 2 of 2

