



United States Department of the Interior

BUREAU OF RECLAMATION
Oklahoma-Texas Area Office
Oklahoma City Field Office
5924 NW 2nd Street, Suite 200
Oklahoma City, OK 73127-6514

IN REPLY REFER TO:
OK-AD
2.2.3.19

MAY 31 2018

Mr. Mark Skiles
City Manager
City of Clinton
415 West Gary Boulevard
Clinton, OK 73601

Subject: City of Clinton, Oklahoma Proposed Crossing of the Clinton Lateral in the Southeast Quarter of the Southwest Quarter of Section 16, Township 12 North, Range 17 West of the Indian Meridian in Custer County, Oklahoma, with a 6-inch Treated Wastewater Transmission Pipeline, Washita Basin Project, Foss Division, Oklahoma

Dear Mr. Skiles:

This letter describes the conditions under which the Bureau of Reclamation does not object to the proposed 6-inch treated wastewater pipeline crossing of the Clinton Lateral in the subject location, to be operated by the City of Clinton (City). The crossing will be at approximate Station No. 608+40 of the Clinton Lateral as shown on the enclosed plan and profile drawings. The referenced conditions are:

1. The City shall advise the Foss Reservoir Master Conservancy District (District) at 580-592-4421 in sufficient time to permit, if necessary, inspection on behalf of the United States of any approved work in progress and at the completion of work within the United States right-of-way.
2. The City will accomplish installation, operation, and maintenance of the wastewater pipeline within the United States right-of-way in a manner which avoids damage to or obstruction of the Washita Basin Project facilities or interference in any way with the operation and maintenance of these facilities. Except as approved in writing, The City will not remove or place additional overburden on United States right-of-way.
3. The wastewater pipeline crossing shall be constructed under the Clinton Lateral by boring method with suitable fill between the wastewater pipeline and borehole annulus to ensure no settling of the ground around the Clinton Lateral occurs. Boring shall begin at a point no closer than 10 feet from the centerline of the lateral, continuing with a minimum clearance of 3 feet below the lateral for a total of 10 feet below grade, ending at a point 10

fact on the other side of the centerline of the lateral. The pipeline crossing will be made using materials that comply with Oklahoma Department of Transportation pipeline safety regulations.

4. The crossing shall be adequately marked to identify the wastewater pipeline.
5. Upon completion of the pipeline installation, The City will provide Reclamation with a scaled as-built engineering drawing of the crossing.
6. The City assumes the entire responsibility for the installation, maintenance, and use of the subject wastewater pipeline within the United States right-of-way. The City understands that should damage occur to the pipeline as a result of the operation, maintenance, repair or replacement of the Clinton Lateral, repairs to the pipeline shall be The City's sole responsibility. Nothing herein shall ever be construed to place upon the United States or the District any manner of liability for injury to or death of person or persons, or for damage to or loss of property arising from or in any manner connected with the installation, maintenance, or use of the subject pipeline.
7. The City agrees that the United States, its officers, agents, employees, and its successors and assigns shall not be held liable for any improvements or works by reason of the exercise of the rights herein reserved; nor shall anything contained in this paragraph be construed in any manner as limiting other reservations in favor of the United States contained in this letter.
8. The conditions of this letter shall inure to the benefit of and be binding upon the successors and assigns of Reclamation and the City.
9. The conditions of this letter shall continue so long as the subject pipeline remains in the United States right-of-way.
10. All rights acquired by the United States at the crossing location, including the right of ingress and egress, remain in full force and effect.

Prior to initiating any construction in the Reclamation right-of-way, an authorized official from the City of Clinton shall acknowledge receipt and acceptance of these conditions by completing the signature and date spaces below on both copies of this letter, then returning one original letter

to this office and retaining the other original letter for the City's files. If you have any questions, please feel free to contact me at 405-470-4800.

Sincerely,



Jeff Tompkins,
Supervisor, Resource Management Division

Enclosures – 2

In Duplicate

ACCEPTANCE:

SIGNATURE _____ **DATE** _____

TITLE _____

cc: Mr. Shawn Dewees
Superintendent
Foss Reservoir Master Conservancy District
HC 66, Box 102
Foss, OK 73647

Mr. Lonnie Teel
CEO
Teel Consulting, Inc.
P.O. Box 531
Clinton, OK 73601
(w/encl to each)